

LOUISIANA

MUNICIPAL WATER POLLUTION PREVENTION

MWPP



Facility Name:

City of Thibodaux
North Thibodaux WWTP

LPDES Permit Number:

LA0127208

Agency Interest (AI) Number:

203695

Address:

P.O. BOX 5418

Thibodaux, LA 70301

Parish:

Lafourche Parish

(Person Completing Form) Name:

Shawn Troxler
Josh Bourgeois

Title:

Consultant
Director of Public Works

Date Completed:

February 26, 2025

INSTRUCTIONS

1. Complete only the sections of the Environmental Audit which apply to your wastewater treatment system. Leave sections that do not apply blank and enter a "0" for the point value.
2. Parts 1 through 7 contain questions for which points may be generated. These points are intended to communicate to the department and the governing body or owner what actions will be necessary to prevent effluent violations. Place the point totals from parts 1 through 7 on the Point Calculation page.
3. Add up the point totals.
4. Submit the Environmental Audit to the governing body or owner for review and approval.
5. The governing body must pass a resolution which contains the following items:
 - a. The resolution or letter must acknowledge the governing body or owner has reviewed the Environmental Audit.
 - b. This resolution must indicate specific actions, if any, will be taken to maintain compliance and prevent effluent violations. Proposed actions should address the parts where maximum or close to maximum points were generated in the Environmental Audit.
 - c. The resolution should provide any other information the governing body deems appropriate.

Permit #:

0 LA 0127208

PART I: INFLUENT FLOW/LOADINGS (all plants)

A. List the average monthly volumetric flows and BOD loadings received at your facility during the last reporting year.

Column 1 Average Monthly Flow (million gallons per day, MGD)		Column 2 Average Monthly BOD5 Concentration (mg/l)		Column 3 Average Monthly BOD5 Loading (pounds per day, lb/day)
1.005	x	62.4	x 8.34 =	523
.898	x	98.6	x 8.34 =	738
.973	x	74.1	x 8.34 =	601
.685	x	215	x 8.34 =	1,228
.56	x	350	x 8.34 =	1,635
.592	x	149	x 8.34 =	736
.934	x	29.4	x 8.34 =	229
.659	x	381	x 8.34 =	2,094
.892	x	472	x 8.34 =	3,511
.502	x	198	x 8.34 =	829
.562	x	74.6	x 8.34 =	350
.517	x	73.9	x 8.34 =	319

BOD loading = Average Monthly Flow (in MGD) x Average Monthly BOD concentration (in mg/l) x 8.34

B. List the design flow and design BOD loading for your facility in the blanks below. If you are not aware of these design quantities, refer to your Operation and Maintenance (O&M) Manual or contact your consulting engineer.

Design Flow, MGD:	1.500	x 0.90 =	1.35
Design BOD, lb/day:	1,500	x 0.90 =	1,350

Permit #:

0 LA 0127208

C. How many months did the monthly flow (Column 1) to the wastewater treatment facility (WWTF) exceed 90% of design flow? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<input checked="" type="radio"/> 0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	<input checked="" type="radio"/> 0	0	0	0	0	5	5	5	5	5	5	5	5

Write 0 or 5 in the C point total box C Point Total

D. How many months did the monthly flow (Column 1) to the WWTF exceed the design flow? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<input checked="" type="radio"/> 0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	<input checked="" type="radio"/> 0	5	5	10	10	15	15	15	15	15	15	15	15

Write 0, 5, 10 or 15 in the D point total box D Point Total

E. How many months did the monthly BOD loading (Column 3) to the WWTF exceed 90% of the design loading? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<input checked="" type="radio"/> 0	1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	<input checked="" type="radio"/> 0	0	5	5	5	10	10	10	10	10	10	10	10

Write 0, 5, or 10 in the E point total box E Point Total

F. How many months did the monthly BOD loading (Column 3) to the WWTF exceed the design loading? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	<input checked="" type="radio"/> 1	2	3	4	5	6	7	8	9	10	11	12
<i>points</i>	0	<input checked="" type="radio"/> 10	20	30	40	50	50	50	50	50	50	50	50

Write 0, 10, 20, 30, 40 or 50 in the F point total box F Point Total

G. Add together each point total for C through F and place this sum in the box below at the right.

TOTAL POINT VALUE FOR PART 1: (max = 80)

Also enter this value or 80, whichever is less, on the point calculation table on page 16.

Permit #:

0 LA 0127208

PART 2: EFFLUENT QUALITY / PLANT PERFORMANCE

A. List the monthly average effluent BOD and TSS concentrations produced by your facility during the last reporting year.

Month	Column 1 Average Monthly BOD (mg/l)	Column 2 Average Monthly TSS (mg/l)
January 2024	34	26.8
February 2024	14.5	18.1
March 2024	12.8	13.9
April 2024	13.6	18.9
May 2024	13.4	8.2
June 2024	7	11.5
July 2024	9.2	13.9
August 2024	27.4	10.3
September 2024	16.1	10.5
October 2024	8.8	11.2
November 2024	23.3	12.3
December 2024	11.5	14.7

B. List the monthly average permit limits for your facility in the blanks below.

	Permit Limit		90% of Permit Limit
BOD, mg/l	10	x 0.90 =	9
TSS, mg/l	15	x 0.90 =	13.5

C. Continuous Discharge to Surface Water.

i. How many months did the effluent BOD (Column 1) exceed 90% of the permit limits? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	9	<u>10</u>	11	12
<i>points</i>	0	0	10	20	30	40	40	40	40	40	<u>40</u>	40	40

Write 0, 10, 20, 30 or 40 in the i point total box 40 i Point Total

ii. How many months did the effluent BOD (Column 1) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	6	7	8	<u>9</u>	10	11	12
<i>points</i>	0	5	5	10	10	10	10	10	10	<u>10</u>	10	10	10

Write 0, 5, or 10 in the ii point total box 10 ii Point Total

iii. How many months did the effluent TSS (Column 2) exceed 90% of the permit limits? Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	3	4	5	<u>6</u>	7	8	9	10	11	12
<i>points</i>	0	0	10	20	30	40	<u>40</u>	40	40	40	40	40	40

Write 0, 10, 20, 30 or 40 in the iii point total box 40 iii Point Total

iv. How many months did the effluent TSS (Column 2) exceed permit limits? Circle the number of months and corresponding point total. Write the point total in the box below at the right.

<i>months</i>	0	1	2	<u>3</u>	4	5	6	7	8	9	10	11	12
<i>points</i>	0	5	5	<u>10</u>	10	10	10	10	10	10	10	10	10

Write 0, 5, or 10 in the iv point total box 10 iv Point Total

v. Add together each point total for i through iv and place this sum in the box below at the right.

TOTAL POINT VALUE FOR PART 2: 100 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

0 LA 0127208

D. Other Monitoring and Limitations

- i.** At any time in the past year was there an exceedance of a permit limit for other pollutants such as: ammonia-nitrogen, phosphorus, pH, total residual chlorine, or fecal coliform?

√ Check one box.

Yes

No

If Yes, Please describe:

<p>Fecal Coliform - Weekly Avg 1/31/24 - 860 2/1/24 - 890 3/26/24 - 718 8/1/24 - 2000</p>

- ii.** At any time in the past year was there a "failure" of a Biomonitoring (Whole Effluent Toxicity) test of the effluent?

√ Check one box.

Yes

No

If Yes, Please describe:

--

- iii.** At any time in the past year was there an exceedance of a permit limit for a toxic substance?

√ Check one box.

Yes

No

If Yes, Please describe:

--

Permit #:

0 LA 0127208

PART 3: AGE OF THE WASTEWATER TREATMENT FACILITY

A. What year was the wastewater treatment facility constructed or last major expansion/improvements completed?

2021

Current Year - Answer to A = Age in years

2024

2021

3

Enter Age in Part C below.

B. ✓ Check the type of treatment facility that is employed.

FACTOR:

<u> X </u>	Mechanical Treatment Plant (trickling filter, activated sludge, etc...) Specify Type: <u> Activated Sludge </u>	2.5
<u> </u>	Aerated Lagoon	2.0
<u> </u>	Stabilization Pond	1.5
<u> </u>	Other Specify Type: _____	1.0

C. Multiply the factor listed next to the type of facility your community employs by the age of your facility to determine the total point value for Part 3.

TOTAL POINT VALUE FOR PART 3 =

$$\frac{2.5}{\text{Factor}} \times \frac{3}{\text{Age}} = \boxed{7.5} \text{ (max = 50)}$$

Also enter this value or 50, whichever is less, on the point calculation table on page 16.

D. Please attach a schematic of the treatment plant.

Permit #:

0 LA 0127208

PART 4: OVERFLOWS AND BYPASSES

A.

- i. List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to heavy rain:

0 ✓ Check one box. 0 = 0 points 3 = 15 points
 1 = 5 points 4 = 30 points
 2 = 10 points 5 or more = 50 points

- ii. List the number of bypasses, overflows or unpermitted discharges shown in A (i) that were within the collection system and the number at the treatment plant

Collection System: 0 Treatment Plant: 0

B.

- i. List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to equipment failure, either at the treatment plant or due to pumping problems in the collection system:

0 ✓ Check one box. 0 = 0 points 3 = 15 points
 1 = 5 points 4 = 30 points
 2 = 10 points 5 or more = 50 points

- ii. List the number of bypasses, overflows or unpermitted discharges shown in B (i) that were within the collection system and the number at the treatment plant

Collection System: 0 Treatment Plant: 0

- C. Specify whether the bypasses came from the city/village/town sewer system or from contract or tributary communities/sanitary districts, etc...

N/A

- D. Add the point values checked for A and B and place the total in the box below.

TOTAL POINT VALUE FOR PART 4: 0 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

- E. List the person responsible (name and title) for reporting overflows, bypasses or unpermitted discharges to State and Federal authorities:

Josh Bourgeois, Director of Public Works

Describe the procedure for gathering, compiling and reporting:

Overflows, bypasses, and unpermitted discharges are submitted by the operator/plant manager and reported to the appropriate agencies (DEQ & SPOC).

PART 5. SEWAGE SLUDGE STORAGE, USE, AND DISPOSAL

A. Sewage Sludge Storage

How many months of sewage sludge storage capacity does your facility have available, either on-site or off-site?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<2	2	3	4-5	6
<i>points</i>	50	30	20	10	0

Write 0, 10, 20, 30 or 50 in the A point total box 0 A Point Total

B. For how many months does your facility have approval to use or dispose of sewage sludge at a properly permitted landfill, land application site, or sewage sludge incinerator?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

<i>months</i>	<6	6-11	12-23	24-35	>36
<i>points</i>	50	30	20	10	0

Write 0, 10, 20, 30 or 50 in the B point total box 0 B Point Total

C. Add together the A and B point values and place the sum in the box below at the right:

TOTAL POINT VALUE FOR PART 5: 0 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

0 LA 0127208

PART 6: NEW DEVELOPMENT

- A. Please provide the following information for the total of all sewer line extensions which were installed during the last year.

Design Population: _____

Design Flow: 1.5 MGD

Design BOD: 125 mg/l

- B. Has an industry (or other development) moved into the community or expanded production in the past year, such that either flow or pollutant loadings to the sewerage system were significantly increased (5% or greater)?

√ Check one box. Yes = 15 points No = 0 points

If Yes, Please describe:

List any new pollutants:

None

- C. Is there any development (industrial, commercial or residential) anticipated in the next 2-3 years, such that either flow or pollutant loadings to the sewerage system could significantly increase?

√ Check one box. Yes = 15 points No = 0 points

If Yes, Please describe:

List any new pollutants you anticipate:

- D. Add together the point value checked in B and C and place the sum in the box below.

TOTAL POINT VALUE FOR PART 6: (max = 30)

Also enter this value or 30, whichever is less, on the point calculation table on page 16.

Permit #:

0 LA 0127208

PART 7: OPERATOR CERTIFICATION AND EDUCATION

A. What was the name of the operator-in-charge for the reporting year?

Name: Josh Bourgeois

B. What is his or her certification number:

Cert.#: 17-490

C. What level of certification is the operator-in-charge required to have to operate the wastewater treatment facility?

Level Required: III

D. What is the level of certification of the operator-in-charge?

Level Certified: IV

E. Was the operator-in-charge of the report year certified at least at the grade level required in order to operate this plant?

√ Check one box. Yes = 0 points No = 50 points

Write 0 or 50 in the E point total box E Point Total

F. Has the operator-in-charge maintained recertification requirements during the reporting year?

√ Check one box. Yes No

G. How many hours of continuing education has the operator-in-charge completed over the last two calendar years?

√ Check one box. > 12 hours = 0 points < 12 hours = 50 points

Write 0 or 50 in the G point total box G Point Total

H. Is there a written policy regarding continuing education an training for wastewater treatment plant employees?

√ Check one box. Yes No

Explain: Training is paid for by the City

I. What percentage of the continuing education expenses of the operator-in-charge were paid for:

By the permittee? 100% By the operator? 0%

J. Add together the E and G point values and place the sum in the box below at the right.

TOTAL POINT VALUE FOR PART 7: (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:

0 LA 0127208

PART 8: FINANCIAL STATUS

A. Are User-Charge Revenues sufficient to cover operation and maintenance expenses?

√ Check one box.

Yes

No

If No, How are O&M costs financed?

N/A

B. What financial resources do you have available to pay for your wastewater improvements and reconstruction needs?

Financial Grants

PART 9: SUBJECTIVE EVALUATION

A. Collection System Maintenance

i. Describe what sewer system maintenance work has been done in the last year.

Unknown

ii. Describe what lift station work has been done in the last year.

Connection of new lift station to increase flow at the North Plant

iii. What collection system improvements does the community have under construction for the next 5 years?

Unknown

B. If you have ponds please answer the following questions:

√ Check one box.

- | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>i. <i>Do you have duckweed buildup in the ponds?</i></p> <p>ii. <i>Do you mow the dikes regularly (at least monthly), to the waters edge?</i></p> <p>iii. <i>Do you have bushes or trees growing on the dikes or in the ponds?</i></p> <p>iv. <i>Do you have excess sludge buildup (> 1foot) on the bottom of any of your ponds?</i></p> <p>v. <i>Do you exercise all of your valves?</i></p> <p>vi. <i>Are your control manholes in good structural shape?</i></p> <p>vii. <i>Do you maintain at least 3 feet of freeboard in all of your ponds?</i></p> <p>viii. <i>Do you visit your pond system at least weekly?</i></p> | <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

C. Treatment Plants

i. Have the influent and effluent flow meters been calibrated in the last year?

Yes No (√ Check one box.)

2/26/2025
Influent flow meter calibration date(s)

2/26/2025
Effluent flow meter calibration date(s)

ii. What problems, if any, have been experienced over the last year that have threatened treatment?

Short Staffed

iii. Is your community presently involved in formal planning for treatment facility upgrade?

√ Check one box. Yes No *If Yes, Please describe:*

N/A

D. Preventive Maintenance

i. Does your plant have a written plan for preventive maintenance on major equipment items?

√ Check one box. Yes No *If Yes, Please describe:*

Contracts with third party to complete repairs and maintenance

ii. Does this preventive maintenance program depict frequency of intervals, types of lubrication and other preventive maintenance tasks necessary for each piece of equipment?

Yes No

iii. Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assured properly?

Yes No

E. Sewer Use Ordinance

i. Does your community have a sewer use ordinance that limits or prohibits the discharge of excessive conventional pollutants (BOD, TSS or pH) or toxic substances to the sewer system from industries, commercial users and residences?

√ Check one box. Yes No *If Yes, Please describe:*

ii. Has it been necessary to enforce?

√ Check one box. Yes No *If Yes, Please describe:*

iii. Any additional comments about your treatment plant or collection system? (Attach additional sheets if necessary.)

Permit #:

0 LA 0127208

POINT CALCULATION TABLE

	Actual Values	Maximum
Part 1: <i>Influent Flow/Loadings</i>	<u>10</u>	80 points
Part 2: <i>Effluent Quality / Plant Performance</i>	<u>100</u>	100 points
Part 3: <i>Age of WWTF</i>	<u>7.5</u>	50 points
Part 4: <i>Overflows and Bypasses</i>	<u>10</u>	100 points
Part 5: <i>Ultimate Disposition of Sludge</i>	<u>0</u>	100 points
Part 6: <i>New Development</i>	<u>0</u>	30 points
Part 7: <i>Operator Certification Training</i>	<u>0</u>	100 points

TOTAL POINTS:

117.5

ATTACHMENT 3

SAMPLE MWPP RESOLUTION

Resolved that the village/town/city of _____ informs the Louisiana Department of Environmental Quality that the following actions were taken by _____ (governing body).

1. Resolved the Municipal Water Pollution Prevention Environmental Audit Report which is attached to this resolution.
2. Set forth the following actions necessary to maintain permit requirements contained in the Louisiana Pollution Discharge Elimination System (LPDES) permit, number LA_____.

(Please be specific in listing the actions that will be taken to address the problems identified in the audit report.)

a.

b.

c.

d.

etc..

Passed by a majority/unanimous (circle one) vote of the _____ on _____ (date).

CLERK