

# SOUTHERN COATINGS, LLC



August 25, 2025

City of Thibodaux  
310 W 2<sup>nd</sup> Street  
Thibodaux, La. 70301

RE: Project: **Canal Street/Candy Lane Water Tower Painting**  
**Change Order #2 Request- Candy Lane Tank Site**

- **Upon Southern Coatings LLC beginning the work on the Candy Lane Water Tank. There have been a few issues that have been encountered.**

## **SCOPE OF WORK**


**ITEM #1- Add clips to the overflow pipe: At the Pre-Construction Meeting John Burgos requested that we stabilize the overflow pipe. There are clips every 50' when there should be clips every 10'. Southern Coatings LLC will install by welding ¼" x 6" metal clips (approximately 10 clips) to the overflow pipe to re-enforce stability to the overflow pipe.**

**TOTAL PRICE: \$ 6020.00**

**ITEM #2- LADDER GATE - The ladder gate is the stainless steel gate at the bottom of the ladder that prevents individuals from accessing the tank . The ladder gate is bent and all bolts are rotten. Southern Coatings LLC will install a new 3M DBI-SALA HINGED HEAVY GUAGE ALUMINUM LOCKING GATE. Please see attached photo.**

**TOTAL PRICE: \$ 4609.00**

1064 Maurice Rd.  
Broussard, La 70518  
[tina@southerncoatings.com](mailto:tina@southerncoatings.com) cell: 318-359-9027

  
Christina Torres/Member  
Louisiana License #71151

# SOUTHERN

COATINGS, LLC



**ITEM #3- Bowl Ladder is Broke and Twisted: Southern Coatings LLC will Straighten the ladder. Weld the ladder back together. Weld and Add New Clips to stabilize the ladder. Please see photos.**

**TOTAL PRICE: \$ 5389.00**

---

Kevin Clement/Mayor  
City of Thibodaux  
310 W 2<sup>nd</sup> Street  
Thibodaux, La. 70301

*Christina Torres*  
Christina Torres/Member  
Southern Coatings LLC  
1064 Maurice Road  
Broussard, La. 70518

*Dan Foglesone*  
Dan Foglesone, PE  
Process and Control Engineering  
9 Flamingo Street  
New Orleans, La 70124  
8/25/25

1064 Maurice Rd.  
Broussard, La 70518  
[tina@southerncoatings.com](mailto:tina@southerncoatings.com) cell: 318-359-9027